



T リンク通信カード
T-Link Communications Card
" OPC-TL "

日本語

ENGLISH

Copyright © 2021 Fuji Electric Co., Ltd.
All rights reserved.

この取扱説明書の著作権は、富士電機株式会社にあります。
本書に掲載されている会社名や製品名は、一般に各社の商標または登録商標です。
仕様は予告無く変更することがあります。

No part of this publication may be reproduced or copied without prior written permission from Fuji Electric Co., Ltd.

All products and company names mentioned in this manual are trademarks or registered trademarks of their respective holders.

The information contained herein is subject to change without prior notice for improvement.

日本語版

日本語

まえがき

Tリンク通信カード「OPC-TL」をお買い上げいただきましてありがとうございます。

この通信カードを富士低圧インバータ FRENIC シリーズに取り付けることで、富士プログラマブルコントローラ MICREX シリーズ（Tリンクモジュール）と接続し、運転指令・速度指令・機能コードアクセス等を使ってインバータをスレーブとしてコントロールすることができます。

この取扱説明書にはインバータに関する取扱い方の記載はありませんので、ご使用前には、この説明書とインバータ本体の取扱説明書をお読みになって取扱い方を理解し、正しくご使用ください。間違った取扱いは、正常な運転を妨げ、寿命の低下や故障の原因になります。

取扱説明書はご使用後も大切に保管してください。

関連資料

「OPC-TL」に関連する資料を以下に示します。目的に応じてご利用ください。

- ・ RS-485 通信ユーザズマニュアル
- ・ インバータの取扱説明書
- ・ インバータのユーザズマニュアル

資料は随時改訂していますので、ご使用の際には最新版の資料を入手してください。



注意

- この取扱説明書を読み、理解したうえで、Tリンク通信カードの取付け、接続（配線）、運転、保守点検を行ってください。
- 間違った取扱いは、正常な運転を妨げたり、寿命の低下や故障の原因になります。
- この取扱説明書は、実際に使用される最終需要家に確実にお届けください。最終需要家はこの取扱説明書を、Tリンク通信カードが廃棄されるまで大切に保管してください。

■ 安全上のご注意

取付け、配線（接続）、運転、保守点検の前に必ずこの取扱説明書を熟読し、製品を正しく使用してください。更に、機器の知識、安全に関する情報および注意事項のすべてについても十分に習熟してください。

この取扱説明書では、安全注意事項のランクは下記のとおり区別されています。

 警告	取扱いを誤った場合に危険な状況が起こる可能性があり、死亡または重傷を負う事故の発生が想定される場合
 注意	取扱いを誤った場合に危険な状況が起こる可能性があり、中程度の傷害や軽傷を受ける事故または物的損害の発生が想定される場合


なお、注意に記載した事項の範囲内でも状況によっては重大な結果に結びつく可能性があります。いずれも重要な内容を記載していますので必ず守ってください。

取付けおよび配線について



- ・ 設置や配線の開始、各種スイッチの切替は、インバータ本体の電源を遮断後にインバータ本体の取扱説明書記載の時間を経過してから、チャージランプの消灯を確認し、テスタなどを使用して主回路端子 P(+)-N(-)間の直流中間回路電圧が安全な値 (DC+25V 以下) に下がっていることを確認してから行ってください。
- ・ 配線作業は、資格のある専門家が行ってください。

感電のおそれあり



- ・ 外部あるいは内部部品が損傷・脱落している製品を使用しないでください。
火災、事故、けがのおそれあり
- ・ 糸くず、紙、木くず、ほこり、金属くずなどの異物がインバータや通信カード内に侵入するのを防止してください。
火災、事故のおそれあり
- ・ 製品の取付け、取外し時に不適切な作業を行うと、製品が破損するおそれがあります。
故障のおそれあり
- ・ インバータ、モータ、配線からノイズが発生します。周辺のセンサや機器の誤動作に注意してください。
事故のおそれあり

操作運転について



- ・ 必ずインバータ本体の表面カバーを取り付けてから電源 ON (閉) してください。なお、通電中はカバーを外さないでください。
- ・ 濡れた手でスイッチを操作しないでください。
感電のおそれあり
- ・ 機能コードのデータ設定を間違えたり、取扱説明書およびユーザーズマニュアルを十分理解しないで機能コードのデータ設定を行うと、機械が許容できないトルクや速度でモータが回転することがあります。インバータの運転の前に各機能コードの確認、調整を行ってください。
事故のおそれあり

保守点検、部品の交換について



- ・ インバータ本体の電源を遮断後にインバータ本体の取扱説明書記載の時間を経過してから、チャージランプの消灯を確認し、テスタなどを使用して主回路端子 P(+)-N(-)間の直流中間回路電圧が安全な値 (DC+25V 以下) に下がっていることを確認してから行ってください。
感電のおそれあり
- ・ 指定された人以外は、保守点検、部品交換をしないでください。
- ・ 作業前に金属物、(時計、指輪など)を外してください。
- ・ 絶縁対策工具を使用してください。

感電、けがのおそれあり

廃棄について

注意

- ・ 製品を廃棄する場合は、産業廃棄物として扱ってください。
けがのおそれあり


その他


警告


- ・ 改造は絶対しないでください。
感電、けがのおそれあり

アイコンについて

本書では以下のアイコンを使用しています。

 **注意** この表示を無視して誤った取扱いをすると、製品が本来持つ性能を発揮できなかつたり、その操作や設定が事故につながるようになります。

 **ヒント** 本製品の操作や設定の際、知っておくと便利な参考事項を示しています。

 参照先を示します。

目次

まえがき	1	第 6 章 T リンク通信までの手順説明	13
■ 安全上のご注意	1	6.1 運転開始手順	13
第 1 章 ご使用のまえに	5	6.2 入出力リレー使用領域	14
1.1 現品の確認	5	6.3 アドレス設定例	14
1.2 対象インバータ	5	第 7 章 通信フォーマット	15
第 2 章 各部の機能・設定	6	7.1 通信フォーマットについて	15
2.1 各部の名称	6	7.2 各通信フォーマットの入出力リレー 使用領域内データ割付アドレス	15
2.2 局番スイッチ	6	7.3 各通信フォーマットの説明	17
2.3 T リンク端子台 (TB11)	6	7.4 実際の通信データの例	25
第 3 章 通信カードの取付けと取外し	7	第 8 章 インバータ本体のアラームコード 一覧	27
3.1 通信カードの取付け	7	第 9 章 保護機能	28
3.2 通信カードの取外し	8	第 10 章 仕様	30
第 4 章 配線	9	10.1 一般仕様	30
4.1 基本接続図	9	10.2 T リンク仕様	31
4.2 T リンク端子台 (TB11) の配線	10		
4.3 インバータへの配線	11		
第 5 章 インバータ機能コードの設定	12		
5.1 関連機能コード	12		
5.2 T リンク通信異常検出時の動作選択	12		

第 1 章 ご使用のまえに

1.1 現品の確認

開梱し次の項目を確認してください。

- (1) 通信カード、ねじ (M3×8 : 2 本)、取扱説明書 (本書) が入っていることを確認してください。
- (2) 通信カード上の部品の異常、凹み、反りなど輸送時での破損がないことを確認してください。
- (3) 通信カード上に形式「OPC-TL」が印刷されていることを確認してください。(図 2.1 参照)

製品にご不審な点や不具合などがありましたら、お買い上げ店または最寄りの弊社営業所までご連絡ください。



本通信カードには終端抵抗は付属していません。終端抵抗は次のものをご使用ください。
100Ω 1W。(MICREX シリーズの T リンクモジュールに付属している終端抵抗器が使用できます。)

1.2 対象インバータ

T リンク通信カードは、下表のインバータ形式および ROM バージョンで使用できます。

表 1.1 適用インバータ形式と ROM バージョン

シリーズ名	インバータ形式	インバータ容量	ROM バージョン
FRENIC-MEGA (G2)	FRN□□□G2□-□□□□	全容量	0100 以降

※ □には、インバータ容量、タイプ、電圧シリーズなどを示す英数字が入ります。

インバータの ROM バージョンは、プログラムモードのメニュー番号 5 「メンテナンス情報」の 5.14 で確認することができます。詳細は、表 1.1 に記載の各インバータ機種 of 取扱説明書を参照してください。

LED モニタの表示	項目	表示内容
5.14	インバータ ROM バージョン	インバータの ROM バージョンを 4 桁で表示します。

第 2 章 各部の機能・設定

2.1 各部の名称

T リンク通信カードの各部の名称を図 2.1 に示します。





図 2.1 T リンク通信カードの各部の名称

2.2 局番スイッチ

局番スイッチ (RSW1, RSW2) によって T リンクの局番の設定を行います。局番の設定範囲は 00~99 です。

注意 局番スイッチの設定はインバータの電源を OFF した状態で実施してください。電源 ON 中に設定を変更した場合は、通信エラーになります。



※1 複数台使用の場合は、局番が重ならないように設定してください。
※2 工場出荷値は、RSW1=0, RSW2=0 (局番=00) となっています。

図 2.2 局番スイッチ (RSW1, RSW2)

2.3 T リンク端子台 (TB11)

T リンクケーブルを接続するための端子台です。

配線に関する詳細は、第 4 章「配線」を参照してください。

第 3 章 通信カードの取付けと取外し



警告

インバータ本体の電源を遮断後にインバータ本体の取扱説明書記載の時間を経過してから、チャージランプの消灯を確認し、テスタなどを使用して主回路端子 P(+)-N(-) 間の直流中間回路電圧が安全な値 (DC+25V 以下) に下がっていることを確認してから行ってください。

感電のおそれあり



注意

- 外部あるいは内部部品が損傷・脱落している製品を使用しないでください。

火災、事故、けがのおそれあり

- 糸くず、紙、木くず、ほこり、金属くずなどの異物がインバータや通信カード内に侵入するのを防止してください。

火災、事故のおそれあり

- 製品の取付け、取外し時に不適切な作業を行うと、製品が破損するおそれがあります。

故障のおそれあり

3.1 通信カードの取付け

注意

インバータ本体の主回路端子および制御回路端子の配線は、通信カードを取り付ける前に行ってください。

- (1) インバータ本体の表面カバーを取り外し、制御プリント基板を露出してください。通信カードは、インバータ本体のオプション接続ポート 3 箇所 (A-, B-, C-port) のうち、A-port にのみ取付け可能です。(図 3.1)



インバータの取扱説明書を参照して表面カバーを取り外してください。(キーボードケースがある場合はキーボードケースも開けてください。)

- (2) 通信カードの裏面 (図 2.1) の CN1 を、インバータ本体の制御プリント基板の A-port (CN4) に差し込み、付属ねじで固定してください。(図 3.3)

注意

通信カードの取付け位置決め部 (図 2.1) がツメ (図 3.2 ①) にセットされ、CN1 (図 3.2 ②) が確実に差し込まれていることを確認してください。図 3.3 は取付け完了を示します。

- (3) 通信カードの配線を行います。



第 4 章「配線」を参照してください。

- (4) インバータ本体の表面カバーを元に戻してください。



インバータの取扱説明書を参照して表面カバーを取り付けてください。(キーボードケースがある場合はキーボードケースも閉じてください。)





図 3.1 FRENIC-MEGA シリーズの例

日本語



① 通信カードをツメに引っ掛けるようにしながらインバータ本体へ位置決めする。

② コネクタをインバータ本体へ挿入する。

注：先にコネクタ側を挿入した場合、挿入が不十分で接触不良となる可能性があります。

図 3.2 通信カードの取付け




図 3.3 取付け完了

3.2 通信カードの取外し

通信カードを取り外す際は、ねじを2ヶ所外し、取外し用つまみ（[図 3.3](#)を参照）を引っぱって取り外してください。

第 4 章 配線



- インバータ本体の電源を遮断後にインバータ本体の取扱説明書記載の時間を経過してから、チャージランプの消灯を確認し、テスタなどを使用して主回路端子 P(+)-N(-)間の直流中間回路電圧が安全な値（DC+25V 以下）に下がっていることを確認してから行ってください。
- 配線作業は、資格のある専門家が行ってください。

感電のおそれあり

- 一般的に制御信号線の被覆は強化絶縁されていませんので、主回路活電部に制御信号線が直接触れると、何らかの原因で絶縁被覆が破壊されることがあります。この場合、制御信号線に主回路の高電圧が印加される危険性がありますので、主回路活電部に制御信号線が触れないように注意してください。

事故のおそれあり，火災のおそれあり



インバータ，モータ，配線からノイズが発生します。周辺のセンサや機器の誤動作に注意してください。

事故のおそれあり

4.1 基本接続図




図 4.1 基本接続図

4.2 Tリンク端子台(TB11)の配線

(1) Tリンクケーブルは下記のケーブルを使用してください。

- ・ 古河電工(株)製ツイストペアケーブル CPEV-SB $\Phi 0.9 \times 1$ 対
- ・ 古河電工(株)製ツイストペアケーブル KPEV-SB $0.5\text{mm}^2 \times 1$ 対

(2) 端子台 (TB11) の配線

端子配列を [図 4.2](#) に、端子機能を [表 4.1](#) に、端子仕様を [表 4.2](#) に示します。




図 4.2 端子配列

表 4.1 端子機能一覧

端子記号	端子名称	端子機能説明
T1	Tリンクケーブル接続端子	Tリンクの通信線を接続する端子。
T2		
SD	シールド	Tリンクケーブルのシールド線を接続する端子。

表 4.2 端子仕様

項目	仕様
ねじサイズ	M3
締付けトルク	0.5N・m

(3) 終端抵抗について

Tリンクは終端抵抗を幹線の両端に外付けすることが必要です。終端抵抗が幹線の両端に接続されていることを確認し、無い場合は必ず接続してください。

注意 本通信カードには終端抵抗は付属していません。終端抵抗は次のものをご使用ください。
100Ω 1W。(MICREX シリーズのTリンクモジュールに付属している終端抵抗器が使用できます。)


4.3 インバータへの配線




↑リンクケーブルは、主回路の配線とは可能な限り離して配線してください。ノイズによる誤動作の要因となります。



通信カードからの配線は、インバータ本体の制御端子台上部と表面カバーの間を通してください。



FRENIC-MEGA シリーズ 0.4kW の例



FRENIC-MEGA シリーズ 75kW の例

図 4.3 配線例

第 5 章 インバータ機能コードの設定

5.1 関連機能コード

インバータで実際に運転を行う前に下の表 5.1 に示すインバータ機能コードの設定をしてください。通信開始直後に T リンク通信異常が発生する恐れもあるので、T リンク通信を行う前に設定することを推奨します。

注意 o30, F80 を変更した後、インバータの電源を再投入してください。

表 5.1 関連機能コード

機能コード	説明	工場出荷値	設定範囲	備考															
o27	T リンク通信異常検出時の動作選択	0	0~15	o27, o28 の詳細は、表 5.2 を参照。															
o28	T リンク通信異常検出時の動作タイマー	0.0s	0.0s~60.0s																
o30	T リンク通信カードの通信フォーマット	0	下記から選択 0: G11 標準フォーマット 2: G9 互換フォーマット 3: 拡張フォーマット 1, 4~255: (使用禁止)	通信フォーマットの詳細は、第 7 章「通信フォーマット」を参照。															
y98	運転・周波数指令元の選択	0	下記から選択 <table border="1" style="margin-left: 20px;"> <thead> <tr> <th>y98</th> <th>周波数指令元 トルク指令元</th> <th>運転指令元</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>インバータ</td> <td>インバータ</td> </tr> <tr> <td>1</td> <td>T リンク</td> <td>インバータ</td> </tr> <tr> <td>2</td> <td>インバータ</td> <td>T リンク</td> </tr> <tr> <td>3</td> <td>T リンク</td> <td>T リンク</td> </tr> </tbody> </table>	y98	周波数指令元 トルク指令元	運転指令元	0	インバータ	インバータ	1	T リンク	インバータ	2	インバータ	T リンク	3	T リンク	T リンク	
y98	周波数指令元 トルク指令元	運転指令元																	
0	インバータ	インバータ																	
1	T リンク	インバータ																	
2	インバータ	T リンク																	
3	T リンク	T リンク																	

注意 o30 を変更した際に、 $\mathcal{E}rS$ が発生することがあります。その場合、MICREX をリセットする必要があります。

5.2 T リンク通信異常検出時の動作選択

T リンク通信に異常を検出した後のインバータの動作を、インバータ機能コード o27 と o28 で選択することができます。表 5.2 に o27, o28 の設定一覧を示します。

なお、通信運転指令または通信周波数指令が有効でない時、 $\mathcal{E}rS$ は発生せず、異常検出時動作も行われません。


表 5.2 o27 および o28 による T リンク通信異常検出時の動作選択

o27	o28	異常検出時の動作	備考
0, 4~9	-	即時フリーラン& $\mathcal{E}rS$ トリップ。	
1	0.0s~60.0s	o28 で設定した時間経過後、フリーラン& $\mathcal{E}rS$ トリップ。	
2	0.0s~60.0s	o28 で設定した時間内に通信リンクが復帰すれば異常を無視。タイムアウトならフリーラン& $\mathcal{E}rS$ トリップ。	
3, 13~15	-	通信異常を無視して現状維持。 ($\mathcal{E}rS$ トリップは発生しません。)	
10	-	即時強制減速。停止後 $\mathcal{E}rS$ トリップ。	強制減速の時間はインバータ機能コード F08 によります。
11	0.0s~60.0s	o28 で設定した時間経過後、強制減速し、停止後 $\mathcal{E}rS$ トリップ。	同上
12	0.0s~60.0s	o28 で設定した時間内に通信リンクが復帰すれば異常を無視。タイムアウトなら強制減速後、 $\mathcal{E}rS$ トリップ。	同上

第 6 章 T リンク通信までの手順説明


6.1 運転開始手順


T リンクの配線が完了した状態から、MICREX とインバータとの間で T リンク通信するまでの手順を説明します。

 T リンク通信することで、MICREX から運転指令の入力や、運転状態のモニタ等を行うことができるようになります。詳細は、第 7 章「通信フォーマット」を参照してください。

(1) MICREX の設定を行います。

- MICREX のローダで、T リンク通信カードの局番（たとえば 00）を設定してください。このとき、リレー領域が他の T リンクの局番と重複しないようにしてください。
- T リンク通信カードの読出し領域、書込み領域の定義を行ってください。フォーマットに関わらず、読出し、書込みともに 4 ワードです。
- I/O グループ設定で、T リンク通信カードを、入力選択としても、出力選択としても登録します。

 占有するリレー領域の詳細に関しては、6.2「入出力リレー使用領域」を参照してください。


 設定方法の詳細は、MICREX のユーザーズマニュアルを参照してください。

(2) 局番スイッチ（RSW1, RSW2）を使って T リンク通信カードの局番を設定します。（2.2 項参照）

- スイッチの設定前に、インバータの電源が OFF されていることを確認してください。
- 局番スイッチを、ローダで設定した局番にあわせませす。

(3) インバータの電源を投入し、インバータ機能コードの設定を行います。

- インバータ機能コード o30 で、通信フォーマットを選択します。
- 必要に応じて、インバータ機能コード o27, o28, y98 の設定をしてください。

 フォーマットの詳細は、第 7 章「通信フォーマット」を参照してください。

(4) MICREX に電源を投入し、T リンクの接続要求を送信します。

 MICREX からの接続要求の送信方法については、MICREX のユーザーズマニュアルを参照してください。


(5) I/O 通信の送受信開始

MICREX と T リンク通信カードの設定が正しく、かつ適正に配線されていれば、MICREX の接続要求に応答して、T リンクの接続が確立します。選択したフォーマットに従ってデータの送受信が行われ、インバータの制御を行うことが可能になります。

MICREX-T リンクモジュールのエラーLED が点灯している場合は、送受信はできません。


6.2 入出力リレー使用領域


Tリンク通信カードは、下図のように入出力リレー領域のうち、インバータ1台につき連続8ワードの領域を使用します。また、局番の2桁の設定（下図のWB00**）は、通信カード上の局番スイッチ（RSW1, RSW2）で行ってください。



6.3 アドレス設定例

(G11 標準フォーマット, 4W+4W の場合)
局番 50 RSW1=5 RSW2=0



 フォーマットの詳細は、第7章「通信フォーマット」を参照してください。

第 7 章 通信フォーマット

7.1 通信フォーマットについて

T リンク通信カードは、G11 標準フォーマット、G9 互換フォーマットと拡張フォーマットの 3 種類の通信フォーマットをサポートしています。

G9 互換フォーマットは、今後サポートされない可能性がありますので、これから T リンクを使用する場合は、G11 標準フォーマットもしくは拡張フォーマットの使用をお勧めします。


表 7.1 機能コード o30 詳細説明

o30	内容	占有ワード
0	G11 標準フォーマット	4W+4W
2	G9 互換フォーマット	4W+4W
3	拡張フォーマット	4W+4W
上記以外* (1, 4~255)	不動作	-


* T リンク通信カードが接続された状態で、o30 を 0, 2 および 3 以外の値に設定しないでください。

7.2 各通信フォーマットの入出カリレー使用領域内データ割付アドレス


(1) G11 標準フォーマット



(2) G9 互換フォーマット



(3) 拡張フォーマット




7.3 各通信フォーマットの説明

(1) G11 標準フォーマット: o30=0 (工場出荷設定値)

本通信フォーマットは、G11 および FRENIC-MEGA シリーズの標準フォーマットです。

これらの機種からの置き換えを行う際には、必ず書込み(読出し)をしている機能コードの確認を行ってから使用してください。

 置き換えを行う際は置き換え先のインバータ機種のユーザーズマニュアルの「置換え時の注意事項」を参照してください。

MIGREX → インバータ

(MSB)

(LSB)

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
4	RST	XR	XF	-	-	X9	X8	X7	X6	X5	X4	X3	X2	X1	REV	FWD
5	極性付き周波数設定 (100%=20000 p. u.)															
6	セレクトィング通信 No.								ポーリング通信 No.							
7	セレクトィングデータ															

FWD : 正転指令

REV : 逆転指令

X1~X9 : 汎用入力 (E01~E09 で機能を設定します)

XF : 汎用入力 (E98 で機能を設定します)

XR : 汎用入力 (E99 で機能を設定します)

RST : リセット信号 (1⇒0 で、インバータアラームを解除) *

周波数設定 : 最高出力周波数 (F03 など) を、20000 とした場合の周波数設定の割合を極性付きで設定

$$\text{周波数指令 [p.u.]} = \frac{\text{周波数指令 [Hz]}}{\text{最高出力周波数 (F03) [Hz]}} \times 20000$$


ポーリング通信 No. : インバータの主要な機能コードから読出しを行うことができます。


セレクトィング通信 No. : インバータの主要な機能コードに書込みを行うことができます。

セレクトィングデータ : セレクトィング通信 No. で指定された機能コードに書込みを行います。

* 通常時は 0 にしてください。

 通信 No. の詳細は、[表 7.2](#) を参照してください。

 インバータ機能コードの設定値はそれぞれ固有のデータフォーマットに従います。データフォーマットの詳細は、RS-485 通信ユーザーズマニュアルの第 5 章「5.2 データフォーマット」を参照してください。

 **注意** 本通信カードの RST 信号は、キーパッドの I/O チェックでは確認できません。

(MSB)

(LSB)

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
0	BUSY	ERR	1	R/L	ALM	DEC	ACC	IL	VL	TL	NUV	BRK	INT	EXT	REV	FWD
1	極性付き出力周波数モニタ (100%=20000 p.u.)															
2	ポーリング通信 No.								空きデータ							
3	ポーリングデータ															

(全て1でON)

FWD : 正転中

REV : 逆転中

EXT : 直流制動中または予備励磁中

INT : インバータ遮断

BRK : 制動中

NUV : 直流中間確立

TL : トルク制限中

VL : 電圧制限中

IL : 電流制限中

ACC : 加速中

DEC : 減速中

ALM : 一括アラーム

R/L : リンク有効/無効 (運転指令または周波数指令のどちらか一方でも通信カードから反映可能なときリンク有効となり, R/LはONとなります)

ERR : セレクティングエラーまたはポーリングエラー *

BUSY : セレクティング中またはポーリング中

出力周波数モニタ : 最高出力周波数 (F03 など) を 20000 (=100%) とした単位, 極性付きで出力周波数をモニタ

ポーリング通信 No. : ポーリング通信 No. で指定した値

ポーリングデータ : ポーリング通信 No. のデータ

* ポーリングまたはセレクティング時に ERR ビットが 1 の場合は, エラーが発生し機能コードの読出しまたは書込みが完了していないことを示します。機能コードが割り当てられていない通信 No. (表 7.2 の EMPTY) が指定されていないか, 「運転中書込み不可」となっている機能コードをインバータ運転中に指定していないか等, を確認してから, 再度, 書込みまたは読出しを行ってください。

G11 標準フォーマットでの機能コードの割付けを表 7.2 に示します。

0 以外の空き通信 No. へのアクセスは、通信エラーとなります。

表 7.2 G11 標準フォーマットでの機能コード通信 No.

通信 No.	機能コード	通信 No.	機能コード	通信 No.	機能コード	通信 No.	機能コード	通信 No.	機能コード	通信 No.	機能コード
1	S01	51	M37	101	EMPTY	151	P01	201	EMPTY	251	EMPTY
2	S02	52	M38	102	EMPTY	152	P02	202	EMPTY	252	EMPTY
3	S03	53	M39	103	EMPTY	153	P03	203	EMPTY	253	EMPTY
4	EMPTY	54	M40	104	EMPTY	154	P06	204	EMPTY	254	EMPTY
5	S05	55	M41	105	EMPTY	155	P07	205	EMPTY	255	EMPTY
6	S06	56	M42	106	E01	156	P08	206	d01		
7	S07	57	M43	107	E02	157	P09	207	d15		
8	S08	58	M44	108	E03	158	P11	208	d03		
9	S09	59	M45	109	E04	159	P12	209	d04		
10	S10	60	M46	110	E05	160	EMPTY	210	d02		
11	S11	61	M47	111	E06	161	EMPTY	211	EMPTY		
12	S13	62	M48	112	E07	162	H07	212	EMPTY		
13	EMPTY	63	M70	113	E08	163	H09	213	EMPTY		
14	EMPTY	64	M74	114	E09	164	F37	214	EMPTY		
15	M01	65	M86	115	E10	165	J03	215	EMPTY		
16	M02	66	M87	116	E11	166	J04	216	EMPTY		
17	M03	67	M88	117	E16	167	J05	217	EMPTY		
18	M04	68	M89	118	E17	168	H28	218	EMPTY		
19	M05	69	EMPTY	119	E20	169	H30	219	EMPTY		
20	M06	70	EMPTY	120	E21	170	A13	220	EMPTY		
21	M07	71	EMPTY	121	E22	171	Y97	221	EMPTY		
22	M08	72	EMPTY	122	E23	172	Y98	222	EMPTY		
23	M09	73	F03	123	E24	173	EMPTY	223	EMPTY		
24	M10	74	F04	124	E30	174	EMPTY	224	EMPTY		
25	M11	75	F05	125	E31	175	EMPTY	225	EMPTY		
26	M12	76	F06	126	E32	176	EMPTY	226	EMPTY		
27	M13	77	F07	127	EMPTY	177	EMPTY	227	EMPTY		
28	M14	78	F08	128	E34	178	EMPTY	228	EMPTY		
29	M15	79	F09	129	E35	179	A01	229	EMPTY		
30	M16	80	F10	130	E98	180	A02	230	EMPTY		
31	M17	81	F11	131	E99	181	A03	231	o27		
32	M18	82	F12	132	EMPTY	182	A04	232	o28		
33	M19	83	F15	133	EMPTY	183	A05	233	o30		
34	M20	84	F16	134	C05	184	A06	234	EMPTY		
35	M21	85	C32	135	C06	185	A07	235	EMPTY		
36	M22	86	F18	136	C07	186	A08	236	EMPTY		
37	M23	87	F20	137	C08	187	A14	237	EMPTY		
38	M24	88	F21	138	C09	188	A15	238	EMPTY		
39	M25	89	F22	139	C10	189	A16	239	EMPTY		
40	M26	90	F23	140	C11	190	A17	240	EMPTY		
41	M27	91	F24	141	EMPTY	191	A20	241	EMPTY		
42	M28	92	F25	142	EMPTY	192	A21	242	EMPTY		
43	M29	93	F40	143	EMPTY	193	A22	243	EMPTY		
44	M30	94	F41	144	EMPTY	194	A23	244	EMPTY		
45	M31	95	F42	145	EMPTY	195	A25	245	EMPTY		
46	M32	96	EMPTY	146	EMPTY	196	A26	246	EMPTY		
47	M33	97	EMPTY	147	EMPTY	197	EMPTY	247	EMPTY		
48	M34	98	EMPTY	148	EMPTY	198	EMPTY	248	EMPTY		
49	M35	99	EMPTY	149	EMPTY	199	EMPTY	249	EMPTY		
50	M36	100	EMPTY	150	EMPTY	200	EMPTY	250	EMPTY		

(2) G9 互換フォーマット: o30=2

本通信フォーマットは、G9 からの置換えの際、MICREX のソフト変更をできる限り少なくするためのものです。ただし、本伝送フォーマットは完全互換動作ではありません。制限内容については、下表を参照してください。

G9 互換フォーマットでの置き換えについて

機能	互換性	対応
運転状態モニタ, 読み出し拡張データ	○	読み出し拡張データは使用しません。
出力周波数	○	
機能コード読み出し	×	M コードは M01(出力電流モニタ), M02(出力電圧モニタ), M03(トルク演算値モニタ)のみ使用可能 (完全互換)
運転指令, 書き込み拡張データ	○	書き込み拡張データは使用しません。
周波数設定	○	
機能コード書き込み	×	

MICREX → インバータ

(MSB)

(LSB)

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
4	-	-	-	-	-	-	-	X5	X4	X3	X2	X1	RST	BX	REV	FWD
5	周波数設定(極性なし) [Hz]															
6	機能コード番号						機能コード種別				要求コード*			BCD		
7	セレクトイングデータ															

G9 フォーマットでは X6~X9 は使用不可です。

FWD : 正転指令

REV : 逆転指令

X1~X5 : 汎用入力 (E01~E05 で機能を設定します)

BX : フリーラン指令

RST : リセット信号 (1⇒0 で、インバータアラームを解除) *1

周波数設定 : 周波数設定値 [Hz] (0.01Hz 刻み) を極性なし値で設定してください。*2

機能コード番号 : 読みしまたは書き込み機能コードの番号を指定します。(BCD)

機能コード種別 : 読みしまたは書き込み機能コードの種別を指定します。

要求コード : 下表の値に設定すると本体に対し、機能コードの読みしまたは書き込みを処理します。

表 7.3 要求コード一覧

要求コード (2進表示)	処理
000b	不動作
001b	書き込み処理
010b	読み出し処理

BCD : 周波数設定を、BCD で行うように切り換えます。(1:BCD, 0:バイナリ)

セレクトイングデータ : セレクトイング機能コードに書き込むデータを設定します。

*1 通常時は0にしてください。

*2 BCD で設定する場合には、0.1Hz 刻みになります。

(例) BCD⇒0 の場合 50.00Hz ⇒ 1368 hex
 BCD⇒1 の場合 50.00Hz ⇒ 0500 hex

注意 本通信カードの RST 信号は、キーパッドの I/O チェックでは確認できません。

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
0	-	-	-	-	-	-	-	-	-	R/L	30	Y5	Y4	Y3	Y2	Y1
1	出力周波数モニタ(極性なし) [Hz]															
2	機能コード番号								機能コード種別				応答コード		BCD	
3	ポーリングデータ															

Y1～Y5 : 汎用出力 (E20～E24 で機能を設定します)

30 : 汎用出力 (E27 で機能を設定します)

R/L : リンク有効/無効 (運転指令または周波数指令のどちらか一方でも通信カードから反映可能なときリンク有効となり, R/L は ON となります)

出力周波数モニタ: 出力周波数モニタ [Hz 単位] (0.01Hz 刻み) は極性なし値です。*

機能コード番号 : インバータ機能コードの数字部 (BCD)

機能コード種別 : 表 7.5 に記載されているコード

応答コード : 要求機能コードの応答を返します。

表 7.4 応答コード一覧

応答コード (2進表示)	状態
000b	・存在しない機能コードにアクセスした
010b	・書き込みまたは読み出し正常完了 ・要求無し
011b	・書き込みまたは読み出し処理中 [BUSY]
100b	・セレクトングデータ範囲外エラー
110b	・パラメータ保護エラー

BCD : モータ出力周波数が, BCD でモニタされているかどうかを示します。
(1:BCD, 0:バイナリ)

ポーリングデータ : 読み出し機能コードのデータ部

* BCD でモニタしている場合には, 0.1Hz 刻みになります。

(例) BCD⇒0 の場合 50.00Hz ⇒ 1368 hex

BCD⇒1 の場合 50.00Hz ⇒ 0500 hex

G9 互換フォーマットでの機能コード設定方法

下記のように、上位 4×2bit の機能コード番号と、4bit の機能コード種別 (表 7.5) とで番号を指定します。




表 7.5 機能コード種別

種別	種別コード	機能コード名称	種別	種別コード	機能コード名称
F *	0	0000b 基本機能	H	6	0110b ハイレベル機能
O	1	0001b オプション機能	A	7	0111b モータ 2 パラメータ
M	2	0010b モニタ機能	J	8	1000b アプリケーション機能 1
E	3	0011b 端子機能	y	9	1001b リンク機能
C	4	0100b 制御機能	d	10	1010b アプリケーション機能 2
P	5	0101b モータ 1 パラメータ			

例：E27 の場合 E ⇒ 0011 (2 進表記)
 27 ⇒ 0010 0111 (2 進表記) } “0010 0111 0011”

* 応答機能コードが F00 (0000 0000 0000b) となっている場合には、機能コード不動作や応答待ちの場合もあります。

G9 互換フォーマットでの M コード

G9 互換フォーマットで M コードにアクセスした場合、下記の特種な機能コードとして、値が読み出されます (書き込み不可)。

表 7.6 M コード一覧

機能コード	名称	値範囲	単位	データフォーマット
M01	出力電流モニタ	0.00~2000	A	②
M02	出力電圧モニタ	0~500	V	①
M03	トルク演算値モニタ	0~255	%	①

以下に G9 互換フォーマットでの M コードデータフォーマットを示します。

データフォーマット①

(MSB) 0 1 2 3 4 5 6 7 8 9 A B C D E F (LSB)

ファンクションデータ × 1 ⇒ 16bit データ

データフォーマット②

(MSB) 0 1 2 3 4 5 6 7 8 9 A B C D E F (LSB)

電流データ (BCD)

指数部

実電流	仮数部	指数部
0.00~9.99	001~999	0
10.0~99.9	100~999	1
100~999	100~999	2
1000~2000	100~200	3

(3) 拡張フォーマット: o30=3

本通信フォーマットを使用することにより、FRENIC-MEGA(G1)シリーズで追加された機能コードにアクセスすることができます。G11 標準フォーマットの機能コードアクセス部を機能コード番号と機能コード種別で指定します。

MICREX → インバータ

(MSB)										(LSB)						
Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
4	RST	XF	XR	-	-	X9	X8	X7	X6	X5	X4	X3	X2	X1	REV	FWD
5	極性付き周波数設定 [最高出力周波数=20000 p. u.]															
6	W/R	機能コード種別						機能コード番号								
7	セレクトイングデータ															

FWD : 正転指令

REV : 逆転指令

X1~X9 : 汎用入力 (E01~E09 で機能を設定します。設定可能な入力点数は機種に依存します。)

XF : 汎用入力 (E98 で機能を設定します)

XR : 汎用入力 (E99 で機能を設定します)

RST : リセット信号 (1⇒0 で、インバータアラームを解除) *

周波数設定 : 速度指令値 [20000p. u.]。極性付きで設定可能です。

$$\text{周波数設定 [p.u.]} = \frac{\text{周波数設定 [Hz]}}{\text{最高出力周波数(F03)[Hz]}} \times \frac{2000}{0}$$

W/R : 1:書き込み命令 0:読出し命令

機能コード種別 : 読出しまたは書き込み機能コードの種別を指定します。

機能コード番号 : 読出しまたは書き込み機能コードの番号を指定します

セレクトイングデータ : セレクトイング機能コードに書き込むデータを設定します。

(MSB)

(LSB)

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F	
0	BUSY	ERR	1	R/L	ALM	DEC	ACC	IL	VL	TL	NUV	BRK	INT	EXT	REV	FWD	
1	極性付き出力周波数モニタ [20000p. u.]																
2	0	機能コード種別							機能コード番号								
3	ポーリングデータ																

FWD : 正転中

REV : 逆転中

EXT : 直流制動中または予備励磁中

INT : インバータ遮断

BRK : 制動中

NUV : 直流中間確立

TL : トルク制限中

VL : 電圧制限中

IL : 電流制限中

ACC : 加速中

DEC : 減速中

ALM : 一括アラーム

R/L : リンク有効/無効 (運転指令または周波数指令のどちらか一方でも通信カードから反映可能なときリンク有効となり, R/LはONとなります)

ERR : セレクティングエラーまたはポーリングエラー *

BUSY : セレクティング中またはポーリング中

出力周波数モニタ : 出力周波数 [20000p. u.]。極性付きでモニタ可能です。

機能コード種別 : [表 7.7](#)に記載されているコード

機能コード番号 : インバータ機能コードの数字部

ポーリングデータ : 読み出し機能コードのデータ部

表 7.7 機能コード種別

種別	種別コード	機能コード名称	種別	種別コード	機能コード名称
S	2	02 _H 指令・機能データ	r	12	0C _H モータ4/速度制御4パラメータ
M	3	03 _H モニタデータ	U	13	0D _H カスタマイズロジック機能
F	4	04 _H 基本機能	J	14	0E _H アプリケーション機能
E	5	05 _H 端子機能	y	15	0F _H リンク機能
C	6	06 _H 制御機能	W	16	10 _H モニタデータ2
P	7	07 _H モータ1パラメータ	X	17	11 _H アラームデータ
H	8	08 _H ハイレベル機能	Z	18	12 _H アラームデータ2
A	9	09 _H モータ2/速度制御2パラメータ	b	19	13 _H モータ3/速度制御3パラメータ
o	10	0A _H オプション機能	d	20	14 _H アプリケーション機能2
L	11	0B _H 特定用途機能			

7.4 実際の通信データの例

G11 標準フォーマット（工場出荷設定）での例を示します。（最高出力周波数 F03=60 Hz とします。）

(1) 運転パターン例

下図のような運転パターンでインバータを制御する場合の通信データ例を示します。




図 7.1 運転パターン

(2) 通信データの説明（文中のデータは Hex 表示です。）

① 指令： 運転指令 OFF。速度指令 1800 r/min (30 Hz = 10000 p.u. = 2710h)。

WB00**	+4	00 00
	+5	27 10
	+6	00 00
	+7	00 00

応答： 停止中。インバータ Ready 状態。

WB00**	+0	30 28
	+1	00 00
	+2	00 00
	+3	00 00

② 指令： 正転指令。速度指令 1800 r/min (=2710h)。

WB00**	+4	00 01
	+5	27 10
	+6	00 00
	+7	00 00

応答： 正転中かつ加速中。出力速度上昇。

WB00**	+0	32 21
	+1	** **
	+2	00 00
	+3	00 00

③ 指令： 正転指令。速度指令 1800 r/min (=2710h)。

WB00**	+4	00 01
	+5	27 10
	+6	00 00
	+7	00 00

応答： 正転中。設定速度到達。

WB00**	+0	30 21
	+1	27 10
	+2	00 00
	+3	00 00

④ 指令：運転指令 OFF。速度指令 1800 r/min(=2710h)。

WB00**	+4	00 00
	+5	27 10
	+6	00 00
	+7	00 00

応答：正転中かつ減速中。出力速度減少。

WB00**	+0	34 21
	+1	** **
	+2	00 00
	+3	00 00

⑤ 指令：運転指令 OFF。速度指令 300 r/min(1667 p. u. =0683h)に変更。

WB00**	+4	00 00
	+5	06 83
	+6	00 00
	+7	00 00

応答：停止中。インバータ Ready 状態。

WB00**	+0	30 28
	+1	00 00
	+2	00 00
	+3	00 00

第 8 章 インバータ本体のアラームコード一覧

インバータ本体のトリップ時のアラーム内容を T リンク経由で確認することができます。以下のインバータ機能コードに、表 8.1 に示すアラームコードが格納されています。

- インバータ通信専用機能コード M16, M17, M18 および M19 (最新アラーム, 1 回前, 2 回前および 3 回前)

表 8.1 アラームコード一覧

アラーム コード M16~M19	内容		アラーム コード M16~M19	内容	
0 (00 _H)	アラームなし	---	33 (21 _H)	CPU エラー	Er3
1 (01 _H)	過電流(加速中)	0L1	34 (22 _H)	オプション通信エラー (通信カードハードエラー)	Er4
2 (02 _H)	過電流(減速中)	0L2	35 (23 _H)	オプションエラー (T リンク通信エラー)	Er5
3 (03 _H)	過電流(一定速中)	0L3	36 (24 _H)	運転操作エラー	Er6
5 (05 _H)	地絡	EF	37 (25 _H)	チューニングエラー	Er7
6 (06 _H)	過電圧(加速中)	0U1	38 (26 _H)	RS-485 通信エラー (通信ポート 1)	Er8
7 (07 _H)	過電圧(減速中)	0U2	42 (2A _H)	脱調検出	ErD
8 (08 _H)	過電圧 (一定速中または停止中)	0U3	43 (2B _H)	モータ選択エラー	ErL
10 (0A _H)	不足電圧	LU	44 (2C _H)	モータ 3 過負荷	0L3
11 (0B _H)	入力欠相	Lin	45 (2D _H)	モータ 4 過負荷	0L4
14 (0E _H)	ヒューズ断	FUS	46 (2E _H)	出力欠相	0PL
16 (10 _H)	充電回路異常	PbF	47 (2F _H)	速度不一致 (速度偏差過大)	ErE
17 (11 _H)	冷却フィン過熱	0H1	50 (32 _H)	磁極位置検出異常	ErC
18 (12 _H)	外部アラーム	0H2	51 (33 _H)	不足電圧時 データセーブエラー	ErF
19 (13 _H)	インバータ内過熱	0H3	52 (34 _H)	位置偏差過大	dU
20 (14 _H)	モータ保護 (PTC/NTC サーミスタ)	0H4	53 (35 _H)	RS-485 通信エラー (通信ポート 2)	ErP
22 (16 _H)	制動抵抗器過熱	dbH	54 (36 _H)	ハードウェアエラー	ErH
23 (17 _H)	モータ 1 過負荷	0L1	56 (38 _H)	位置制御エラー	ErO
24 (18 _H)	モータ 2 過負荷	0L2	57 (39 _H)	STO 入力 (EN1, EN2) 回路異常	ErF
25 (19 _H)	インバータ過負荷	0LU	58 (3A _H)	電流入力断線検出	LoF
27 (1B _H)	過速度保護	0S	59 (3B _H)	制動トランジスタ故障	dbB
28 (1C _H)	PG 断線	PG	65 (41 _H)	カスタマイズロジックエラー	ErL
29 (1D _H)	NTC サーミスタ断線	nr6	66 (42 _H)	PID 制御 1 フィードバック異常検出	PU1
31 (1F _H)	メモリエラー	Er1	67 (43 _H)	PID 制御 2 フィードバック異常検出	PU2
32 (20 _H)	キーボード通信エラー	Er2	68 (44 _H)	USB 通信エラー	ErU

表 8.1 アラームコード一覧

アラーム コード M16~M19	内容		アラーム コード M16~M19	内容	
70 (46 _H)	充電抵抗過熱	<i>GH6</i>	121 (79 _H)	ユーザ定義アラーム 1	<i>EA1</i>
81 (51 _H)	湯水保護	<i>Pdr</i>	122 (7A _H)	ユーザ定義アラーム 2	<i>EA2</i>
82 (52 _H)	高頻度運転保護	<i>rcl</i>	123 (7B _H)	ユーザ定義アラーム 3	<i>EA3</i>
83 (53 _H)	大水量保護	<i>Pol</i>	124 (7C _H)	ユーザ定義アラーム 4	<i>EA4</i>
84 (54 _H)	噛み込み防止保護	<i>rl0</i>	125 (7D _H)	ユーザ定義アラーム 5	<i>EA5</i>
85 (55 _H)	フィルタ目詰まり異常	<i>Fol</i>	250 (FA _H)	バッテリー不足	<i>lob</i>
91 (5B _H)	外部 PID1 フィードバック異常検出	<i>PUR</i>	251 (FB _H)	日時情報喪失	<i>dll</i>
92 (5C _H)	外部 PID2 フィードバック異常検出	<i>PUB</i>	252 (FC _H)	強制運転	<i>Fod</i>
93 (5D _H)	外部 PID3 フィードバック異常検出	<i>PUL</i>	253 (FD _H)	パスワード保護	<i>lop</i>
100 (64 _H)	DC ファンロック検出	<i>FAL</i>	254 (FE _H)	模擬故障	<i>Err</i>

第 9 章 保護機能

インバータ本体で T リンク通信カードが異常であると判断した場合、 $E_r G$ または $E_r S$ が表示され、トリップします。その場合、下記に従って通信カードの確認を行ってください。

オプション通信エラー(通信カードハードエラー) ($E_r G$)

現象 通信カードとインバータ本体間の通信エラーが発生した。

原因	チェックと対策
(1) 通信カードとインバータ本体の接続に不具合がある	通信カードのコネクタとインバータ本体のコネクタが正しく嵌合しているかを確認する。 →通信カードを正しく本体に装着する。
(2) 周囲から強いノイズを受けた	ノイズ対策(接地の状態, 信号線や通信ケーブル/主回路配線の設置方法など)を確認する。 →ノイズ対策を改善する。
(3) 同一通信カードが2枚以上搭載されている。	同一通信カードが2枚以上搭載されていないか確認する。 →インバータ1台に対し, 同一通信カードは1枚のみとする。
(4) 通信カードが2枚以上搭載されている。	他の通信カード(DeviceNet等)が搭載されていないか確認する。 →インバータ1台に対し, 通信カードは1枚のみとする。

オプションエラー(Tリンク通信エラー) ($E_r S$)

現象 通信カードでエラーが発生した。

原因	チェックと対策
(1) T リンク局番の不一致	T リンクの局番が MICREX 側設定と一致しているか確認する。 →T リンク通信カードの局番スイッチ(RSW1, RSW2)で設定し直す。
(2) T リンクのデータ領域の重複	T リンクの局番設定が他の機器と重なっていないか確認する。 →T リンクの局番設定を見直す。 詳細は, MICREX ユーザーズマニュアルを参照してください。
(3) T リンクケーブルの配線の不適合	T リンクケーブルのケーブルの状態, 配線方法を確認する。 →断線したケーブルは交換し, 配線方法を適切にする。
(4) 周囲から強いノイズを受けた。	ノイズ対策(接地の状態, 信号線や通信ケーブル/主回路配線の設置方法など)を確認する。 →ノイズ対策を改善する。
(5) 終端抵抗の不適合	仕様通りの終端抵抗が正しく取り付けられているか確認する。 →仕様通りの終端抵抗を正しく取り付ける。
(6) 他のオプションカードでエラーが発生している。	どのオプションカードが発生原因かを確認する。 → $E_r S$ の原因となっているオプションカードの取扱説明書を参照してください。

第 10 章 仕様

10.1 一般仕様

本通信カードの使用環境を表 10.1 に示します。記載のない項目については、インバータ本体の仕様に準じます。

表 10.1 本通信カードの使用環境

項目	仕様
場所	適用インバータ本体の取扱説明書を参照
動作周囲湿度	5～95%（結露しないこと）
雰囲気	塵埃、直射日光、腐食性ガス、可燃性ガス、オイルミスト、蒸気、水滴がないこと。（汚染度 2（IEC60664-1））（注） 塩分があまり含まれていないこと。（年間 0.01 mg/cm ² 以下） 急激な温度変化による結露が生じないこと。
標高	1,000m 以下
気圧	86～106 kPa

（注）糸屑や湿り気を帯びた塵埃など冷却フィンが目詰まりが生じる環境に据え付けしないでください。このような環境で使う場合、糸屑などが入らない制御盤内に据え付けてください。

10.2 Tリンク仕様

本通信カードのTリンク仕様を表10.2に示します。記載のない項目については、Tリンクの仕様に基づきます。

表 10.2 Tリンク仕様

項目	仕様	
名称	Tリンク通信カード	
型式	OPC-TL	
適合インバータ ROM バージョン	「1.2 対象インバータ」を参照してください。	
適合コントローラ	MICREX シリーズ	
伝送仕様	Tリンクスレーブ I/O 伝送	
伝送占有ワード数	計 8 ワード (MICREX→インバータ:4W, インバータ→MICREX:4W)	
Tリンクケーブル	古河電工(株)製ツイストペアケーブル CPEV-SBφ0.9×1 対 または 古河電工(株)製ツイストペアケーブル KPEV-SB0.5mm ² ×1 対	
接続可能台数	12 台	
最大伝送速度	500kbps	
運 転	運転指令	正転・逆転指令, アラームリセット指令, X1~X9·XF·XR 指令 (G11 標準フォーマット, 拡張フォーマット) 正転・逆転指令, アラームリセット指令, X1~X5 指令, BX 指令 (G9 互換フォーマット)
	周波数設定, 出力周波数モニタ	設定(出力)周波数×20000÷最高周波数(F03)→16ビットデータ (G11 標準フォーマット, 拡張フォーマット) 設定分解能[バイナリコード0.01Hz], [BCDコード0.1Hz] (G9 互換フォーマット)
	運転状態モニタ	正転, 逆転, 直流制動中, インバータ遮断, 制動中, 直流中間確立, トルク制限中, 電圧制限中, 電流制限中, 加速中, 減速中, 一括アラーム, リンク有効/無効状態, Tリンクからの書込み/読出しエラー, データ書込み(処理)中信号のモニタが可能です。 (G11 標準フォーマット, 拡張フォーマット) Y1~Y5 端子による運転中, 周波数到達, 周波数レベル検出など汎用出力信号, 一括アラーム信号, リンク有効/無効状態のモニタが可能です。 (G9 互換フォーマット)
	機能コード	主要な機能コードに対して読出し/書込みが可能です。読出し/書込み可能な機能コードについては, 第7章の表7.2「G11 標準フォーマットでの機能コード通信 No.」を参照してください。 (G11 標準フォーマット) F, o, E, C, P, H, A, J, y, dコードの読出し/書込みが可能です。 Mコードは出力電流, 出力電圧, 演算トルク値のみを読出し可能です。 (G9 互換フォーマット) 主要な機能コードに対して読出し/書込みが可能です。読出し/書込み可能な機能コードについては, 第7章の表7.7「機能コード種別」を参照してください。 (拡張フォーマット)
	Tリンク通信エラー 発生時の復帰	o27の設定により, 異常検出時の動作を選択します。異常によりアラームが発生した場合は, アラーム要因解除後に, リセット指令にて動作が復帰します。
	アラーム内容の確認	Mコードによりアラーム内容の確認が可能です。(G11 標準フォーマット, 拡張フォーマット)

項目	仕様
保護機能	<i>Ers</i> : オプション通信エラー (通信カードハードエラー) (通信カードとインバータ間の通信エラー) <i>Ers</i> : オプションエラー (I リンク通信エラー) (MICREX と通信カードとの通信エラー)

English Version

ENGLISH

Preface

Thank you for purchasing our T-Link Communications Card "OPC-TL".

The communications card is used to connect our general-purpose inverter FRENIC series to a T-Link network. Mounting this communications card on your inverter allows you to connect the inverter to a Fuji MICREX series of programmable logic controllers (T-Link module) and control it as a slave unit using run and frequency commands, and accessing function codes.

This instruction manual does not contain inverter handling instructions. Read through this instruction manual in conjunction with the inverter instruction manual and be familiar with proper handling and operation of this product. Improper handling might result in incorrect operation, a short life, or even a failure of this product.

Keep this manual in a safe place.

Related Publications

Listed below are the other materials related to the use of the T-Link communications card "OPC-TL" Read them in conjunction with this manual as necessary.

- RS-485 Communication User's Manual
- Inverter's instruction manual
- Inverter's user's manual

The materials are subject to change without notice. Be sure to obtain the latest editions for use.



CAUTION

- Read through this instruction manual and be familiar with the T-Link communications card before proceeding with installation, connections (wiring), operation, or maintenance and inspection.
- Improper handling might result in incorrect operation, a short life, or even a failure of this product as well as the motor.
- Deliver this manual to the end user of this product. Keep this manual in a safe place until this product is discarded.

■ Safety precautions

Read this manual thoroughly before proceeding with installation, connections (wiring), operation, or maintenance and inspection. Ensure you have sound knowledge of the device and familiarize yourself with all safety information and precautions before proceeding to operate the inverter.

Safety precautions are classified into the following two categories in this manual.

 WARNING	Failure to heed the information indicated by this symbol may lead to dangerous conditions, possibly resulting in death or serious bodily injuries.
 CAUTION	Failure to heed the information indicated by this symbol may lead to dangerous conditions, possibly resulting in minor or light bodily injuries and/or substantial property damage.

Failure to heed the information contained under the CAUTION title can also result in serious consequences. These safety precautions are of utmost importance and must be observed at all times.

Installation and wiring

WARNING

- Before starting installation and wiring, or changing the switches, turn OFF the power and wait for the recommended time described in an applicable inverter's instruction manual to elapse.
Make sure that the charging lamp is turned OFF.
Further, make sure, using a multimeter or a similar instrument, that the DC link bus voltage between the terminals P(+) and N(-) has dropped to the safe level (+25 VDC or below).
- Qualified electricians should carry out wiring.
Otherwise, an electric shock could occur.

CAUTION

- Do not use the product that is damaged or lacking parts.
Doing so could cause a fire, an accident, or injuries.
- Prevent lint, paper fibers, sawdust, dust, metallic chips, or other foreign materials from getting into the inverter and the communications card.
Otherwise, a fire or an accident might result.
- Incorrect handling in installation/removal jobs could cause a failure.
A failure might result.
- Noise may be emitted from the inverter, motor and wires. Implement appropriate measure to prevent the nearby sensors and devices from malfunctioning due to such noise.
Otherwise, an accident could occur.

Operation

WARNING

- Be sure to install the front cover before turning the inverter's power ON. Do not remove the cover when the inverter power is ON.
Otherwise, an electric shock could occur.
- Do not operate switches with wet hands.
Doing so could cause an electric shock.
- If you configure the function codes wrongly or without completely understanding inverter's instruction manual and the inverter's user's manual, the motor may rotate with a torque or at a speed not permitted for the machine. Confirm and adjust the setting of the function codes before running the inverter.
Otherwise, an accident could occur.

Maintenance and inspection, and parts replacement

WARNING

- Turn OFF the power and wait for the recommended time described in an applicable inverter's instruction manual to elapse. Make sure that the charging lamp is turned OFF.
Further, make sure, using a multimeter or a similar instrument, that the DC link bus voltage between the terminals P(+) and N(-) has dropped to the safe level (+25 VDC or below).
Otherwise, an electric shock could occur.
- Maintenance, inspection, and parts replacement should be made only by qualified persons.
- Take off the watch, rings and other metallic objects before starting work.
- Use insulated tools.
Otherwise, an electric shock or injuries could occur.

Disposal

CAUTION

- Treat the communications card as an industrial waste when disposing of it.
Otherwise injuries could occur.

Others

WARNING

- Never modify the communications card.
Doing so could cause an electric shock or injuries.

Icons

The following icons are used throughout this manual.



This icon indicates information which, if not heeded, can result in the product not operating to full efficiency, as well as information concerning incorrect operations and settings which can result in accidents.



This icon indicates information that can prove handy when performing certain settings or operations.



This icon indicates a reference to more detailed information.

Table of Contents

Preface	1	Chapter 6..... ESTABLISHING A T-Link COMMUNICATIONS LINK	13
■ Safety precautions.....	1	6.1 Starting Procedure.....	13
Chapter 1 BEFORE USE.....	5	6.2 I/O Relay Area Occupied.....	14
1.1 Acceptance Inspection	5	6.3 Address Configuration Example	14
1.2 Applicable Inverters	5	Chapter 7 COMMUNICATIONS FORMAT	15
Chapter 2 NAMES AND FUNCTIONS.....	6	7.1 About Communications Format	15
2.1 Parts Names.....	6	7.2 Data Allocation Addresses in I/O Relay Area	15
2.2 Station Address Switches (RSW1 and RSW2)	6	7.3 Descriptions of Communications Formats	17
2.3 T-Link Terminal Block (TB11).....	6	7.4 Example of Communication Data	23
Chapter 3 INSTALLATION AND REMOVAL OF THE COMMUNICATIONS CARD	7	Chapter 8 LIST OF INVERTER ALARM CODES	27
3.1 Installing the Communications Card	7	Chapter 9 PROTECTIVE FUNCTIONS.....	29
3.2 Removing the Communications Card.....	8	Chapter 10 SPECIFICATIONS	30
Chapter 4 WIRING AND CABLING	9	10.1 Operating Environment.....	30
4.1 Basic Connection Diagram	9	10.2 T-Link Specifications.....	31
4.2 Wiring for T-Link Terminal Block (TB11).....	10		
4.3 Wiring to Inverter	11		
Chapter 5 CONFIGURING INVERTER'S FUNCTION CODES FOR T-Link COMMUNICATION	12		
5.1 Inverter's Function Codes.....	12		
5.2 Error Processing for T-Link Network Breaks.....	12		

Chapter 1 BEFORE USE

1.1 Acceptance Inspection

Unpack the package and check the following:

- (1) A communications card, two screws (M3 × 8), and the T-Link Communications Card Instruction Manual (this document) are contained in the package.
- (2) The communications card is not damaged during transportation--no defective parts, dents or warps.
- (3) The model name "OPC-TL" is printed on the communications card. (See Figure 2.1.)

If you suspect the product is not working properly or if you have any questions about your product, contact the shop where you bought the product or your local Fuji branch office.



No terminating resistor comes with this communications card.

A pair of resistors with the following specifications must be used: 100 ohm, 1 watt

(The terminating resistors that come with the T-Link module of the MICREX series can be used.)

1.2 Applicable Inverters

The T-Link communications card is applicable to the following inverters and ROM version.

Table 1.1 Applicable Inverters and ROM Version

Inverter series	Inverter type	Applicable motor rating	ROM version
FRENIC-MEGA(G2)	FRN□□□G2□-□□□	All capacities	0100 or later

* The boxes □ replace alphanumeric letters depending on the nominal applied motor, enclosure, power supply voltage, etc.

To check the inverter's ROM version, use Menu #5 "Maintenance Information" on the keypad. (Refer to the instruction manual of the inverter series shown in Table 1.1.)

Display on LED Monitor	Item	Description
5. /4	Inverter's ROM version	Shows the inverter's ROM version as a 4-digit code.

Chapter 2 NAMES AND FUNCTIONS

2.1 Parts Names

Figure 2.1 shows the names of the parts on the T-Link communications card.





Figure 2.1 Names of Parts on T-Link Communications Card

2.2 Station Address Switches (RSW1 and RSW2)

The station address switches on the communications card are rotary ones (RSW1 and RSW2) that are used to configure the station address of the communications card on a T-link. The setting range is from 00 to 99.

Note The station address switches should be accessed when the inverter power is OFF. Access with the inverter power ON will result in a communications error.




Note 1: When two or more communications cards are used on the same T-Link network, the same station address should not be double assigned.

Note 2: Factory default: RSW1 = 0, RSW2 = 0 (Station address = 00)

Figure 2.2 Station Address Switches (RSW1 and RSW2)

2.3 T-Link Terminal Block (TB11)

Connect the T-Link communications cable to the T-Link terminal block.

 For details about wiring, refer to Chapter 4 "WIRING AND CABLING."

Chapter 3 INSTALLATION AND REMOVAL OF THE COMMUNICATIONS CARD

⚠ WARNING ⚠

Turn OFF the power and wait for the recommended time described in an applicable inverter's instruction manual to elapse. Make sure that the charging lamp is turned OFF. Further, make sure, using a multimeter or a similar instrument, that the DC link bus voltage between the terminals P(+) and N(-) has dropped to the safe level (+25 VDC or below).
Otherwise, an electric shock could occur.


⚠ CAUTION ⚠

- Do not use the product that is damaged or lacking parts.
Doing so could cause a fire, an accident, or injuries.
- Prevent lint, paper fibers, sawdust, dust, metallic chips, or other foreign materials from getting into the inverter and the communications card.
Otherwise, a fire or an accident might result.
- Incorrect handling in installation/removal jobs could cause a failure.
A failure might result.

3.1 Installing the Communications Card

Note Before mounting the communications card, perform the wiring for the main circuit terminals and control circuit terminals.


- (1) Remove the front cover from the inverter and expose the control printed circuit board (control PCB). As shown in [Figure 3.1](#), the communications card can be connected to the A-port only, out of three option connection ports (A-, B-, and C-ports) on the control PCB.

 To remove the front cover, refer to the inverter's instruction manual. For inverters with the keypad enclosure, open also the keypad enclosure.


- (2) Insert connector CN1 on the back of the communications card (Figure 1.1) into the A-port (CN4) on the inverter's control PCB. Then secure the communications card with the two screws that come with the card. (Figure 3.3)

Note Check that the positioning cutout (shown in [Figure 2.1](#)) is fitted on the tab (① in [Figure 3.2](#)) and connector CN1 is fully inserted (② in [Figure 3.2](#)). Figure 3.3 shows the communications card correctly mounted.

- (3) Wire to the communications card.

 For details, refer to Chapter 4 "WIRING AND CABLING."

- (4) Put the front cover back into place.

 To put back the front cover, refer to the inverter's instruction manual.

For inverters with the keypad enclosure, close also the keypad enclosure.





Figure 3.1 In the case of FRENIC-MEGA series



- ① Fit the positioning cutout of the communications card over the tab on the inverter to determine the mounting position.
- ② Insert connector CN1 on the communications card into the corresponding port on the inverter's control PCB.

Note: Be sure to follow the order of ① and ②. Inserting CN1 first may lead to insufficient insertion, resulting in a contact failure.

Figure 3.2 Mounting the Communications Card




Figure 3.3 Mounting Completed

3.2 Removing the Communications Card

Remove the two screws that secure the communications card and pull the release knob (shown in [Figure 3.3](#)) to take the communications card out of the inverter.

Chapter 4 WIRING AND CABLING

⚠ WARNING ⚠

- Before starting wiring, or changing the switches, turn OFF the power and wait for the recommended time described in an applicable inverter's instruction manual to elapse. Make sure that the charging lamp is turned OFF.
Further, make sure, using a multimeter or a similar instrument, that the DC link bus voltage between the terminals P(+) and N(-) has dropped to the safe level (+25 VDC or below).
- Qualified electricians should carry out wiring.
Otherwise, an electric shock could occur.
- In general, the covers of the control signal wires are not specifically designed to withstand a high voltage (i.e., reinforced insulation is not applied). Therefore, if a control signal wire comes into direct contact with a live conductor of the main circuit, the insulation of the cover might break down, which would expose the signal wire to a high voltage of the main circuit. Make sure that the control signal wires will not come into contact with live conductors of the main circuit.
Failure to observe this precaution could cause an electric shock or an accident.

⚠ CAUTION ⚠

Noise may be emitted from the inverter, motor and wires. Take appropriate measures to prevent the nearby sensors and devices from malfunctioning due to such noise.
An accident could occur.

4.1 Basic Connection Diagram




Figure 4.1 Basic Connection Diagram

4.2 Wiring for T-Link Terminal Block (TB11)

- (1) Use either of the following cables as a T-Link communications cable.
 - Twisted pair cable CPEV-SB 0.9 dia. x 1 pair (manufactured by Furukawa Electric)
 - Twisted pair cable KPEV-SB 0.5 mm² x 1 pair (manufactured by Furukawa Electric)
- (2) Wiring to T-Link terminal block (TB11)

The pin assignment on the T-Link terminal block, the terminal functions, and the terminal specifications are shown in [Figure 4.2](#), Tables 4.1 and 4.2, respectively.




Figure 4.2 Pin Assignment on T-Link Terminal Block

Table 4.1 Functions of T-Link Terminals

Symbol	Name	Functions
T1	T-Link terminals	Terminals for connecting the T-Link communications line
T2		
SD	Shield	Terminal for connecting the cable shield

Table 4.2 Terminal Specifications

Item	Specifications
Terminal screw size	M3
Tightening torque	0.5 N·m

(3) Terminating resistor


T-Link requires a terminating resistor to be mounted externally on each end of the trunk line. Check that the trunk line is terminated on both ends; if it is not terminated, mount a terminating resistor(s) on the missing end(s).

Note No terminating resistor comes with this communications card.


A pair of resistors with the following specifications must be used: 100 ohm, 1 watt
(The terminating resistors that come with the T-Link module of the MICREX series can be used.)

4.3 Wiring to Inverter

- Note** Route the T-Link communications cable as far from the wiring of the main circuit as possible. Otherwise electric noise may cause malfunctions.
- Note** Pass the T-Link communications cable between the control circuit terminal block and the front cover.



In the case of the FRENIC-MEGA series without the keypad enclosure



In the case of the FRENIC-MEGA series with the keypad enclosure

Figure 4.3 Examples of Wiring

Chapter 5 CONFIGURING INVERTER'S FUNCTION CODES FOR T-Link COMMUNICATION

5.1 Inverter's Function Codes

Before running the inverter for practical operation, configure the inverter's function codes listed in [Table 5.1](#). It is recommended to configure them before starting T-Link communication, since a T-Link network break could occur immediately after the start of communication.

Note After changing o30 or F80, turn on the power of the inverter again.

Table 5.1 Inverter's Function Code Settings Required for T-Link Communication

Function codes	Description	Factory default setting	Function code data	Remarks															
o27	Select error processing for T-Link network breaks	0	0 to 15	For details about function codes o27 and o28, see Table 5.2.															
o28	Set the operation timer to be used in error processing for network breaks	0.0 s	0.0 to 60.0 s																
o30	Specify T-link communications format	0	Select one of the following: 0: G11 standard format 2: G9 compatible format 3: Enhanced format 1, 4 to 255: (Not allowed)	For details about communications format, refer to Chapter 7.															
y98	Select run/frequency command sources	0	Select from the following choices: <table border="1" style="margin-left: 20px;"> <thead> <tr> <th>y98</th> <th>Frequency /Torque command source</th> <th>Run command source</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>Inverter</td> <td>Inverter</td> </tr> <tr> <td>1</td> <td>T-Link</td> <td>Inverter</td> </tr> <tr> <td>2</td> <td>Inverter</td> <td>T-Link</td> </tr> <tr> <td>3</td> <td>T-Link</td> <td>T-Link</td> </tr> </tbody> </table>	y98	Frequency /Torque command source	Run command source	0	Inverter	Inverter	1	T-Link	Inverter	2	Inverter	T-Link	3	T-Link	T-Link	
y98	Frequency /Torque command source	Run command source																	
0	Inverter	Inverter																	
1	T-Link	Inverter																	
2	Inverter	T-Link																	
3	T-Link	T-Link																	

Note Changing o30 data may cause an option error (T-Link communications error) $\mathcal{E}r5$. If it occurs, reset the MICREX.

5.2 Error Processing for T-Link Network Breaks

Inverter's function codes o27 and o28 define error processing that the inverter should perform when it detects a T-Link network break, as listed in [Table 5.2](#).

If no run or frequency command via the communications link is enabled, the inverter does not issue $\mathcal{E}r5$, performing no error processing.


Table 5.2 Error Processing for T-Link Network Breaks, Defined by Function Codes o27 and o28

o27	o28	Error Processing after Detection of T-Link Network Break	Remarks
0, 4 to 9	Invalid	Immediately coast to a stop and trip with $\mathcal{E}r5$.	
1	0.0 to 60.0 s	After the time specified by o28, coast to a stop and trip with $\mathcal{E}r5$.	
2	0.0 to 60.0 s	If the communications link is restored within the time specified by o28, ignore the communications error. If a timeout occurs, coast to a stop and trip with $\mathcal{E}r5$.	
3,13 to 15	Invalid	Continue to run, ignoring the error (No $\mathcal{E}r5$ trip).	
10	Invalid	Immediately decelerate to a stop. After the stop, trip with $\mathcal{E}r5$.	The inverter's function code F08 specifies the deceleration time.
11	0.0 to 60.0 s	After the time specified by o28, decelerate to a stop. After the stop, trip with $\mathcal{E}r5$.	Same as above.
12	0.0 to 60.0 s	If the communications link is restored within the time specified by o28, ignore the communications error. If a timeout occurs, decelerate to a stop and trip with $\mathcal{E}r5$.	Same as above.

Chapter 6 ESTABLISHING A T-Link COMMUNICATIONS LINK


6.1 Starting Procedure

After confirming that wiring to the T-Link has been completed, establish a T-Link communications link between the MICREX and the inverter and start T-Link communication, using the procedure given in this chapter.

 T-Link communication enables the MICREX to issue run commands and monitor the inverter's operation. For details, refer to Chapter 7 "COMMUNICATIONS FORMAT."

(1) Configure the MICREX.

- Set a station address of the T-Link communications card (e.g., 00) using the MICREX loader. The relay area should not be double assigned by any other T-Link station address.
- Allocate read and write areas on the T-Link communications card. Each of those areas is 4 words in length, regardless of the format.
- In the I/O group setting, register the T-Link communications card as both input and output devices.

 For details about the relay area to be occupied, refer to Chapter 6, Section 6.2 "I/O Relay Area Occupied."


 For details about configuring MICREX, refer to the MICREX user's manual.

(2) Configure the station address switches (RSW1 and RSW2) on the communications card. (Refer to Section 2.2.)


- Before accessing the station address switches, make sure that the inverter power is turned OFF.
- Set the station address switches to the station address that matches the one specified by the loader.

(3) Turn the inverter power ON and configure the inverter's function codes.

- Select the communications format with the inverter's function code o30.
- Configure the inverter's function codes o27, o28, and y98, if necessary.

 For details about the communications format, refer to Chapter 7 "COMMUNICATIONS FORMAT."

(4) Power ON the MICREX and send a T-Link connection request to the inverter.

 For details about how to send a connection request from the MICREX, refer to the MICREX user's manual.

(5) Start I/O data exchange.


In response to the connection request from the MICREX, the T-Link communications link will be established if the MICREX and the T-Link communications card have been properly configured and wiring between them is correct.

The MICREX exchanges data with the inverter in accordance with the communications format selected, making it possible to control the inverter.

When the error LED on the MICREX T-Link module is ON, no T-Link communication is possible.

6.2 I/O Relay Area Occupied


T-Link communication uses a consecutive eight-word area per inverter in the I/O relay area as shown below. The two-digit address (** in WB00**) should be configured with rotary switches RSW1 and RSW2 on the communications card.




6.3 Address Configuration Example

In the case of G11 standard format, 4 W + 4 W

Station address 50: RSW1 = 5, RSW2 = 0



 For details about communications format, refer to Chapter 7 "COMMUNICATIONS FORMAT."

Chapter 7 COMMUNICATIONS FORMAT

7.1 About Communications Format

The T-Link communications card supports three types of communications formats: G11 standard format, G9 compatible format and the Enhanced format.

Use of the G11 standard format or the Enhanced format are recommended since the G9 compatible format may not be supported in the future.


Table 7.1 Details of Function Code o31

Data for o30	Function	Occupied Words
0	G11 standard format	4 W + 4 W
2	G9 compatible format	4 W + 4 W
3	Enhanced format	4 W + 4 W
Other than the above * (1, 4 to 255)	Disable	--


* Do not set the o30 data to any values other than "0", "2" and "3" with the T-Link communications card connected.

7.2 Data Allocation Addresses in I/O Relay Area


(1) G11 Standard Format



(2) G9 Compatible Format




(3) Enhanced Format



7.3 Descriptions of Communications Formats

(1) G11 standard format: o30 = 0 (factory default)

The G11 standard format is common to the G11 and FRENIC-MEGA series of inverters. Be sure to confirm function codes that are used for reading/writing before replacing target inverter.

 For details about the function codes to confirm, refer to the inverter's user's manual, "Replacement Information".

MICREX → Inverter

	(MSB)													(LSB)		
Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
4	RST	XR	XF	-	-	X9	X8	X7	X6	X5	X4	X3	X2	X1	REV	FWD
5	Signed frequency command (Maximum frequency = 20000 p.u.)															
6	Selecting communication number								Polling communication number							
7	Selecting data															

FWD: Run forward command

REV: Run reverse command

X1 to X9: General-purpose input (whose functions are specified by E01 to E09)

XF: General-purpose input (whose function is specified by E98)

XR: General-purpose input (whose function is specified by E99)

RST: Reset signal (Turning RST from "1" to "0" releases an inverter alarm.)
(This data should be "0" in ordinary operation.)


Frequency command: Signed frequency command to be specified, assuming that the maximum frequency (e.g., F03) is 20000 (=100%)


$$\text{Frequency command [p.u.]} = \frac{\text{Frequency command [Hz]}}{\text{Maximum frequency (F03) [Hz]}} \times 20000$$


Polling communication number: Can be read from the inverter's major function codes

Selecting communication number: Can be written into the inverter's major function codes

Selecting data: Can be written into the function code specified by the "Selecting communication number"

 For details about the communication number, refer to [Table 7.2](#).

 The inverter's function code data is subject to the data format of each function code. For details about the data format, refer to the RS-485 Communication User's Manual, Chapter 5, Section 5.2 "Data Formats."

 **Note** The RST signal received via the communications card cannot be checked in "I/O Checking" on the keypad.

Inverter → MICREX

(MSB)

(LSB)

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
0	BUSY	ERR	1	R/L	ALM	DEC	ACC	IL	VL	TL	NUV	BRK	INT	EXT	REV	FWD
1	Signed output frequency monitor (Maximum frequency = 20000 p.u.)															
2	Polling communication number								Empty data							
3	Polling data															

(Each item is ON when its data is "1.")

FWD: Running forward

REV: Running reverse

EXT: During DC braking or pre-exciting

INT: Inverter shutdown

BRK: Braking

NUV: DC link bus voltage established

TL: Torque limiting

VL: Output voltage limiting

IL: Output current limiting

ACC: During acceleration

DEC: During deceleration

ALM: Alarm relay output

R/L: Link enabled/disabled (When either one of run and frequency commands can be specified via the communications card, the link becomes enabled and the R/L is turned ON.)

ERR: Selecting or polling error *

BUSY: Selecting or polling

Output frequency monitor: Signed output frequency under monitoring, assuming that the maximum frequency (e.g., F03) is 20000 (=100%)

Polling communication number: Value specified by the polling communication number

Polling data: Data specified by the polling communication number

* If the ERR bit is "1" during polling or selecting, an error has occurred so that reading or writing of a function code is not completed. Check your specification conditions such as: whether a communication number having no function code assignment (EMPTY in [Table 7.2](#)) is specified or a function code having the attribute of "writing not allowed during running" is specified when the inverter is running. Then try reading/writing again.

The table below lists the correspondence between the communication numbers (COM#) and FRENIC-MEGA function codes in the G11 standard format.

Accessing any of the EMPTY COM numbers other than 0 will cause a communications error.

Table 7.2 Correspondence Between the COM# and Function Codes in the G11 Standard Format

COM #	Function code	COM #	Function code	COM #	Function code	COM #	Function code	COM #	Function code	COM #	Function code
1	S01	51	M37	101	EMPTY	151	P01	201	EMPTY	251	EMPTY
2	S02	52	M38	102	EMPTY	152	P02	202	EMPTY	252	EMPTY
3	S03	53	M39	103	EMPTY	153	P03	203	EMPTY	253	EMPTY
4	EMPTY	54	M40	104	EMPTY	154	P06	204	EMPTY	254	EMPTY
5	S05	55	M41	105	EMPTY	155	P07	205	EMPTY	255	EMPTY
6	S06	56	M42	106	E01	156	P08	206	d01		
7	S07	57	M43	107	E02	157	P09	207	d15		
8	S08	58	M44	108	E03	158	P11	208	d03		
9	S09	59	M45	109	E04	159	P12	209	d04		
10	S10	60	M46	110	E05	160	EMPTY	210	d02		
11	S11	61	M47	111	E06	161	EMPTY	211	EMPTY		
12	S13	62	M48	112	E07	162	H07	212	EMPTY		
13	EMPTY	63	M70	113	E08	163	H09	213	EMPTY		
14	EMPTY	64	M74	114	E09	164	F37	214	EMPTY		
15	M01	65	M86	115	E10	165	J03	215	EMPTY		
16	M02	66	M87	116	E11	166	J04	216	EMPTY		
17	M03	67	M88	117	E16	167	J05	217	EMPTY		
18	M04	68	M89	118	E17	168	H28	218	EMPTY		
19	M05	69	EMPTY	119	E20	169	H30	219	EMPTY		
20	M06	70	EMPTY	120	E21	170	A13	220	EMPTY		
21	M07	71	EMPTY	121	E22	171	Y97	221	EMPTY		
22	M08	72	EMPTY	122	E23	172	Y98	222	EMPTY		
23	M09	73	F03	123	E24	173	EMPTY	223	EMPTY		
24	M10	74	F04	124	E30	174	EMPTY	224	EMPTY		
25	M11	75	F05	125	E31	175	EMPTY	225	EMPTY		
26	M12	76	F06	126	E32	176	EMPTY	226	EMPTY		
27	M13	77	F07	127	EMPTY	177	EMPTY	227	EMPTY		
28	M14	78	F08	128	E34	178	EMPTY	228	EMPTY		
29	M15	79	F09	129	E35	179	A01	229	EMPTY		
30	M16	80	F10	130	E98	180	A02	230	EMPTY		
31	M17	81	F11	131	E99	181	A03	231	o27		
32	M18	82	F12	132	EMPTY	182	A04	232	o28		
33	M19	83	F15	133	EMPTY	183	A05	233	o30		
34	M20	84	F16	134	C05	184	A06	234	EMPTY		
35	M21	85	C32	135	C06	185	A07	235	EMPTY		
36	M22	86	F18	136	C07	186	A08	236	EMPTY		
37	M23	87	F20	137	C08	187	A14	237	EMPTY		
38	M24	88	F21	138	C09	188	A15	238	EMPTY		
39	M25	89	F22	139	C10	189	A16	239	EMPTY		
40	M26	90	F23	140	C11	190	A17	240	EMPTY		
41	M27	91	F24	141	EMPTY	191	A20	241	EMPTY		
42	M28	92	F25	142	EMPTY	192	A21	242	EMPTY		
43	M29	93	F40	143	EMPTY	193	A22	243	EMPTY		
44	M30	94	F41	144	EMPTY	194	A23	244	EMPTY		
45	M31	95	F42	145	EMPTY	195	A25	245	EMPTY		
46	M32	96	EMPTY	146	EMPTY	196	A26	246	EMPTY		
47	M33	97	EMPTY	147	EMPTY	197	EMPTY	247	EMPTY		
48	M34	98	EMPTY	148	EMPTY	198	EMPTY	248	EMPTY		
49	M35	99	EMPTY	149	EMPTY	199	EMPTY	249	EMPTY		
50	M36	100	EMPTY	150	EMPTY	200	EMPTY	250	EMPTY		

ENGLISH

(2) G9 compatible format: o30 = 2

This format has been designed to minimize software modification required in the MICREX for replacement of the G9 series. Note that this format is not fully compatible. For restrictions, see the table below.

Replacing the G9 series, using the G9 compatible format

Function	Compatibility	Description
Running status monitor, Extended data read	Yes	No extended data read is used.
Output frequency	Yes	
Function code data read	No	In the M code group, only M01 (Output current monitor), M02 (Output voltage monitor), and M03 (Calculated torque value monitor) are available (full-compatible).
Run command, Extended data written	Yes	No extended data written is used.
Frequency command	Yes	
Function code data written	No	

MICREX → Inverter

(MSB)										(LSB)						
Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
4	-	-	-	-	-	-	-	X5	X4	X3	X2	X1	RDT	BX	REV	FWD
5	Frequency command (Hz)															
6	Function code number								Function code group				Request code		BCD	
7	Selecting data															

In G9 format, X6 to X9 are not available.

FWD: Run forward command

REV: Run reverse command

X1 to X5: General-purpose input (to be specified by E01 to E05)

BX: Coast to a stop command

RST: Reset signal (Changing the data from "1" to "0" clears the inverter alarm) *1

Frequency command: Unsigned frequency command value [Hz] (in increments of 0.01 Hz) *2

Function code number: Specifies the function code number from/into which data is read/written. (BCD)

Function code group: Specifies the function code group to be read or written

Request code: Depending on the specified data (see the table below), reading/writing data from/into the inverter is enabled or disabled.

Table 7.3 Request Codes

Request Code (binary)	Processing
000b	Disable
001b	Write
010b	Read

BCD: Switches the frequency command format between binary and BCD. (1: BCD, 0: Binary)

Selecting data: Specifies the data to be written into the selecting function code

*1 This data should be "0" in ordinary operation.

*2 If specified in BCD, the data is expressed in increments of 0.1 Hz.

Example) If BCD data is "0": 50.00 Hz = 1368 hex.

If BCD data is "1": 50.00 Hz = 0500 hex.

 The RST signal received via the communications card cannot be checked in "I/O Checking" on the keypad.

Inverter → MICREX

(MSB)

(LSB)

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
0	-	-	-	-	-	-	-	-	-	R/L	30	Y5	Y4	Y3	Y2	Y1
1	Output frequency monitor (Hz)															
2	Function code number								Function code group				Response code			BCD
3	Polling data															

Y1 to Y5: General-purpose output (to be specified by E20 to E24)

30: General-purpose output (to be specified by E27)

R/L: Link enabled or disabled (When either one of run and frequency commands can be entered via the communications card, the link is regarded as enabled and the R/L is turned ON.)

Output frequency: Unsigned Output frequency monitor in Hz (in increments of 0.01 Hz) *

Function code number: Numeral part of an inverter's function code (BCD)

Function code group: Group code of a function code listed in [Table 7.5](#)

Response code: Returns a response related to the requested function code

Table 7.4 Response Codes

Response Codes (binary)	Status
000b	Accessed to a nonexistent function code
010b	- Writing or reading normally completed - No request
011b	Writing or reading in progress (BUSY)
100b	Selecting data out of range error
110b	Parameter protection error

BCD: Indicates whether the motor output frequency is monitored in BCD format (1: BCD, 0: binary)

Polling data: Data part of a function code read

* If monitored in BCD, the data is expressed in increments of 0.1 Hz.

Example) If BCD data is "0": 50.00 Hz = 1368 hex.
If BCD data is "1": 50.00 Hz = 0500 hex.

Configuring inverter's function codes in G9 compatible format

Configure a function code data by specifying the function code number in binary-coded decimal and the code group in binary (listed in [Table 7.5](#)).




Table 7.5 Function Code Group

Group	Group Code	Function Code	Group	Group Code	Function Code		
F*	0	0000b	Fundamental function	H	6	0110b	High performance function
O	1	0001b	Option function	A	7	0111b	Motor 2 parameters
M	2	0010b	Monitored data	J	8	1000b	Application function 1
E	3	0011b	Terminal function	y	9	1001b	Link function
C	4	0100b	Control function	d	10	1010b	Application function 2
P	5	0101b	Motor 1 parameters				

Example: For E27, E ⇒ 0011 (binary)
 27 ⇒ 0010 0111 (binary) } "0010 0111 0011"

* Function code response F00 (0000 0000 0000b) may mean "function code disabled" or "waiting for response."

M codes in G9 compatible format


Accessed in the G9 compatible format, each of the following M codes serves as a special function code to read the corresponding value. (Writing is not allowed.)

Table 7.6 M Codes


Function Code	Name	Range	Unit	Data Format
M01	Output current monitor	0.00 to 2000	A	[2]
M02	Output voltage monitor	0 to 500	V	[1]
M03	Calculated torque value monitor	0 to 255	%	[1]

Given below are the data formats for M codes in the G9 compatible format.

- Data format [1]



- Data format [2]



Actual Current	Significand	Exponent Part
0.00 to 9.99	001 to 999	0
10.0 to 99.9	100 to 999	1
100 to 999	100 to 999	2
1000 to 2000	100 to 200	3

(3) Enhanced format: o30 = 3

Using this format, the function codes added in the FRENIC-MEGA (G1) series can be accessed. In order to specify those function codes, the function code access section of the G11 standard format (6th word) is replaced with the function code number and function code type.

MICREX → Inverter

	(MSB)											(LSB)				
Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
4	RST	XR	XF	-	-	X9	X8	X7	X6	X5	X4	X3	X2	X1	REV	FWD
5	Signed frequency command (Maximum frequency = 20000 p.u.)															
6	WR	Function code group						Function code number								
7	Selecting data															

FWD: Run forward command

REV: Run reverse command

X1 to X9: General-purpose input (whose functions are specified by E01 to E09)

XF: General-purpose input (whose function is specified by E98)

XR: General-purpose input (whose function is specified by E99)

RST: Reset signal (Turning RST from "1" to "0" releases an inverter alarm.)
(This data should be "0" in ordinary operation.)

Frequency command: Signed frequency command to be specified, assuming that the maximum frequency (e.g., F03) is 20000 (=100%)

$$\text{Frequency command [p.u.]} = \frac{\text{Frequency command [Hz]}}{\text{Maximum frequency (F03) [Hz]}} \times 20000$$

W/R: 1: Write request 0: Read request

Function code number: Specifies the function code number from/into which data is read/written. (BCD)

Function code group: Specifies the function code group to be read or written

Selecting data: Can be written into the function code specified by the "Selecting communication number"

(MSB)

(LSB)

Word	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
0	BUSY	ERR	1	R/L	ALM	DEC	ACC	IL	VL	TL	NUV	BRK	INT	EXT	REV	FWD
1	Signed output frequency monitor (Maximum frequency = 20000 p.u.)															
2	0	Function code group							Function code number							
3	Polling data															

FWD: Running forward

REV: Running reverse

EXT: During DC braking or pre-exciting

INT: Inverter shutdown

BRK: Braking

NUV: DC link bus voltage established

TL: Torque limiting

VL: Output voltage limiting

IL: Output current limiting

ACC: During acceleration

DEC: During deceleration

ALM: Alarm relay output

R/L: Link enabled/disabled (When either one of run and frequency commands can be specified via the communications card, the link becomes enabled and the R/L is turned ON.)

ERR: Selecting or polling error *

BUSY: Selecting or polling

Output frequency monitor: Signed output frequency under monitoring, assuming that the maximum frequency (e.g., F03) is 20000 (=100%)

Function code group: Group code of a function code listed in [Table 7.7](#)

Function code number: Numeral part of an inverter's function code

Polling data: Data specified by the polling communication number

Table 7.7 Function Code Group (Enhanced format)

Group	Group Code		Function Code	Group	Group Code		Function Code
S	2	02h	Command/function data	r	12	0Ch	Motor 4 / Speed Regulator 4 parameters
M	3	03h	Monitored data	U	13	0Dh	Customizable Logic Functions
F	4	04h	Fundamental functions	J	14	0Eh	Application functions
E	5	05h	Terminal functions	y	15	0Fh	Link functions
C	6	06h	Control functions	W	16	10h	Monitor data
P	7	07h	Motor 1 parameters	X	17	11h	Alarm data
H	8	08h	High performance functions	Z	18	12h	Alarm data 2
A	9	09h	Motor 2 / Speed Regulator 2 parameters	b	19	13h	Motor 3 / Speed Regulator 3 parameters
o	10	0Ah	Optional functions	d	20	14h	Application functions 2
L	11	0Bh	Application specific functions				

7.4 Example of Communication Data

This section shows an example of communication data in the G11 standard format (factory default). The example assumes that the maximum frequency (F03) is 60 Hz.

(1) Example of operation pattern

Figure 7.1 shows an example of an inverter's operation pattern. To drive the inverter according to this operation pattern, the communication data should be as shown in item (2) below.




Figure 7.1 Operation Pattern

(2) Communication data (in hexadecimal)

- ① Commands: Run command OFF, Speed command 1800 r/min (30 Hz = 10000 p.u. = 2710h)

WB00**	+4	00 00
	+5	27 10
	+6	00 00
	+7	00 00

Response: Being stopped, Inverter ready

WB00**	+0	30 28
	+1	00 00
	+2	00 00
	+3	00 00

- ② Commands: Run forward command, Speed command 1800 r/min (= 2710h)

WB00**	+4	00 01
	+5	27 10
	+6	00 00
	+7	00 00

Response: Running forward during acceleration, Output speed increasing

WB00**	+0	32 21
	+1	** **
	+2	00 00
	+3	00 00

③ Commands: Run forward command, Speed command 1800 r/min (= 2710h)

WB00**	+4	00 01
	+5	27 10
	+6	00 00
	+7	00 00

Response: Running forward, Arrived at the reference speed

WB00**	+0	30 21
	+1	27 10
	+2	00 00
	+3	00 00

④ Commands: Run command OFF, Speed command 1800 r/min (= 2710h)

WB00**	+4	00 00
	+5	27 10
	+6	00 00
	+7	00 00

Response: Running forward during deceleration, Output speed decreasing

WB00**	+0	34 21
	+1	** **
	+2	00 00
	+3	00 00

⑤ Commands: Run command OFF, Change the speed command to 300 r/min (1667 p.u. = 0683h)

WB00**	+4	00 00
	+5	06 83
	+6	00 00
	+7	00 00

Response: Being stopped, Inverter ready

WB00**	+0	30 28
	+1	00 00
	+2	00 00
	+3	00 00

Chapter 8 LIST OF INVERTER ALARM CODES

Through T-Link, the MICREX can monitor the information on alarms that have occurred in the inverter. Their alarm codes are stored in the inverter's communication-dedicated function codes M16 to M19 (latest, last, 2nd last, and 3rd last alarm codes), as listed below.

Table 8.1 Alarm Codes

Alarm codes in M16 to M19	Description		Alarm codes in M16 to M19	Description	
0 (00 _H)	No alarm	---	33 (21 _H)	CPU error	Er3
1 (01 _H)	Overcurrent (During acceleration)	OL1	34 (22 _H)	Option communications error (Communications card hardware error)	Er4
2 (02 _H)	Overcurrent (During deceleration)	OL2	35 (23 _H)	Option error (T-Link communications error)	Er5
3 (03 _H)	Overcurrent (During running at constant speed)	OL3	36 (24 _H)	Operation protection	Er6
5 (05 _H)	Grounding fault	EF	37 (25 _H)	Tuning error	Er7
6 (06 _H)	Overvoltage (During acceleration)	OU1	38 (26 _H)	RS-485 communications error (COM port 1)	Er8
7 (07 _H)	Overvoltage (During deceleration)	OU2	42 (2A _H)	Out-of-step detection	Er d
8 (08 _H)	Overvoltage (During running at constant speed or stopped)	OU3	43 (2B _H)	Motor selection failure	Er l
10 (0A _H)	Undervoltage	LU	44 (2C _H)	Overload of Motor 3	OL3
11 (0B _H)	Input phase loss	LI n	45 (2D _H)	Overload of Motor 4	OL4
14 (0E _H)	Fuse blown	FUS	46 (2E _H)	Output phase loss	OPL
16 (10 _H)	Charging circuit fault	PbF	47 (2F _H)	Speed mismatch (Excessive speed deviation)	ErE
17 (11 _H)	Heat sink overheat	OH1	50 (32 _H)	Magnetic pole position detection error	ErC
18 (12 _H)	External alarm	OH2	51 (33 _H)	Data saving error during undervoltage	ErF
19 (13 _H)	Inverter internal overheat	OH3	52 (34 _H)	Excessive positioning deviation	dU
20 (14 _H)	Motor protection (PTC/NTC thermistor)	OH4	53 (35 _H)	RS-485 communications error (COM port 2)	ErP
22 (16 _H)	Braking resistor overheat	dbH	54 (36 _H)	Hardware error	ErH
23 (17 _H)	Overload of Motor 1	OL1	56 (38 _H)	Positioning control error	Er o
24 (18 _H)	Overload of Motor 2	OL2	57 (39 _H)	STO input (EN1,EN2) circuit failure	ErF
25 (19 _H)	Inverter overload	OLU	58 (3A _H)	Current input terminal disconnect detection	Er oF
27 (1B _H)	Overspeed	OS	59 (3B _H)	Braking transistor failure	dbA
28 (1C _H)	PG wire disconnection	PG	65 (41 _H)	Customizable logic error	ErL
29 (1D _H)	NTC thermistor wire disconnection	nr b	66 (42 _H)	PID1 feedback error	Pu1
31 (1F _H)	Memory error	Er i	67 (43 _H)	PID2 feedback error	Pu2
32 (20 _H)	Keypad communications error	Er r2	68 (44 _H)	USB communications error	ErU

Table 8.1 Alarm Codes (Continued)

Alarm codes in M16 to M19	Description		Alarm codes in M16 to M19	Description	
70 (46 _H)	Charging resistor overheat	<i>CHS</i>	121 (79 _H)	User-defined alarm 1	<i>LR1</i>
81 (51 _H)	Drought protection	<i>Pdr</i>	122 (7A _H)	User-defined alarm 2	<i>LR2</i>
82 (52 _H)	Control of maximum starts per hour	<i>rol</i>	123 (7B _H)	User-defined alarm 3	<i>LR3</i>
83 (53 _H)	End of curve protection	<i>Pol</i>	124 (7C _H)	User-defined alarm 4	<i>LR4</i>
84 (54 _H)	Anti jam	<i>rLo</i>	125 (7D _H)	User-defined alarm 5	<i>LR5</i>
85 (55 _H)	Filter clogging error	<i>FoL</i>	250 (FA _H)	Low battery	<i>LoB</i>
91 (5B _H)	Feedback error (Exterior PID1)	<i>PUR</i>	251 (FB _H)	Time information loss	<i>dtL</i>
92 (5C _H)	Feedback error (Exterior PID2)	<i>PUB</i>	252 (FC _H)	Forced operation	<i>FoD</i>
93 (5D _H)	Feedback error (Exterior PID3)	<i>PUL</i>	253 (FD _H)	Password protection	<i>LoP</i>
100 (64 _H)	DC fan locked	<i>FRL</i>	254 (FE _H)	Mock alarm	<i>Err</i>

Chapter 9 PROTECTIVE FUNCTIONS

If the inverter judges that any error relating to the T-Link communications card has occurred, it trips with $\mathcal{E}r\ 4$ or $\mathcal{E}r\ 5$ displayed. If this happens, check the communications card following the instructions below.

Option communications error (Communications card hardware error) ($\mathcal{E}r\ 4$)

Problem A communications error occurred between the T-Link communications card and the inverter.

Possible Causes	What to Check and Suggested Measures
(1) There was a problem with the connection between the communications card and the inverter.	Check whether the connector on the communications card is properly engaged with that on the inverter. → Reload the communications card into the inverter.
(2) Strong electrical noise.	Check whether appropriate noise control measures have been implemented (e.g. correct grounding and routing of signal wires, communications cables, and main circuit wires). → Implement noise control measures.
(3) More than one communications card of the same type is mounted.	Check the type of the communications cards mounted on the inverter. → Mount only one communications card of the same type on the inverter.
(4) More than one communications card of different types is mounted.	Check whether any other type of the communications card (e.g., DeviceNet) is mounted. → Mount only one communications card on the inverter.

Option error (T-Link communications error) ($\mathcal{E}r\ 5$)

Problem An error detected by the communications card.

Possible Causes	What to Check and Suggested Measures
(1) Mismatch of T-Link station address.	Check whether the station address specified on the T-Link communications card matches with the one specified at the MICREX. → Configure the station address of the T-Link communications card properly using the station address switches (RSW1 and RSW2).
(2) T-Link data area double assigned.	Check whether the T-Link station address is double assigned by any other device on the same T-Link network. → Review the T-Link station address settings. For details, refer to the MICREX user's manual.
(3) Incorrect wiring of T-Link communications cable	Check the cable specifications and wiring. → Replace the cable if broken and correct the wiring.
(4) Strong electrical noise.	Check whether appropriate noise control measures have been implemented (e.g. correct grounding and routing of signal wires, communications cables, and main circuit wires). → Implement noise control measures.
(5) Improper terminating resistors.	Check whether the terminating resistors are mounted as specified. → Mount the terminating resistors as specified.
(6) Error that has occurred in any other option card.	Find out the option card causing an error. → Refer to the instruction manual of the option card that has caused $\mathcal{E}r\ 5$.

Chapter 10 SPECIFICATIONS

10.1 Operating Environment

[Table 10.1](#) lists the environmental requirements for the inverter equipped with the communications card. For the items not covered in this section, the specifications of the inverter itself apply.

Table 10.1 Environmental Requirements

Item	Specifications
Site location	Refer to an applicable inverter's instruction manual.
Relative humidity	5 to 95% (No condensation)
Atmosphere	The inverter must not be exposed to dust, direct sunlight, corrosive gases, flammable gases, oil mist, vapor or water drops. Pollution degree 2 (IEC60664-1) (Note) The atmosphere can contain a small amount of salt. (0.01 mg/cm ² or less per year) The inverter must not be subjected to sudden changes in temperature that will cause condensation to form.
Altitude	1,000 m max.
Atmospheric pressure	86 to 106 kPa

(Note) Do not install the inverter in an environment where it may be exposed to lint, cotton waste or moist dust or dirt which will clog the heat sink of the inverter. If the inverter is to be used in such an environment, install it in a dustproof panel of your system.

10.2 T-Link Specifications

[Table 10.2](#) lists the T-Link specifications for this communications card. For the items not covered in this section, the specifications of the T-Link apply.

Table 10.2 T-Link Specifications

Item	Specifications	
Name	T-Link communications card	
Model name	OPC-TL	
Applicable inverters	Refer to 1.2 Applicable Inverters	
Applicable controller	MICREX series	
Transmission specifications	T-Link slave I/O transmission	
Number of words occupied in transmission	Total 8 words (MICREX → Inverter: 4 W, Inverter → MICREX: + 4 W)	
T-Link communications cable	Furukawa Electric twisted pair cable CPEV-SB 0.9 dia. x 1 pair or Furukawa Electric twisted pair cable KPEV-SB 0.5 mm ² x 1 pair	
Number of units connectable	Max. 12 units	
Transmission speed	500 kbps	
Operation	Run command	Run forward and reverse commands, Alarm reset command, X1 to X9, XF, and XR commands (G11 standard format, Enhanced format) ----- Run forward and reverse commands, Alarm reset command, X1 to X5, and BX commands (G9 compatible format)
	Reference frequency, output frequency monitor	Reference frequency × 20000 ÷ Maximum frequency (F03) → 16-bit data (G11 standard format, Enhanced format) ----- Reference resolution (binary code 0.01 Hz), (BCD code 0.1 Hz) (G9 compatible format)
	Running status monitor	The following signals can be monitored: Running forward, Running reverse, During DC braking, Inverter shutdown, Braking, DC link bus voltage established, Torque limiting, Output voltage limiting, Output current limiting, During acceleration, During deceleration, Alarm relay output, Link enabled/disabled, Write/read error from the T-Link, and Data writing in progress (G11 standard format, Enhanced format) ----- The following signals can be monitored: General-purpose output signals on terminals Y1 to Y5 (such as inverter running, frequency arrival signal, and frequency detected), Alarm relay output, Link enabled/disabled (G9 compatible format)
	Function codes	Able to read and write data from/to major function codes. For function codes that can be read/written by the T-Link communications card, refer to Chapter 7, Table 7.2 "Correspondence Between the COM# and Function Codes in the G11 standard format." (G11 standard format) ----- Able to read and write data from/to the following function codes: F, o, E, C, P, H, A, J, y, and d codes. Also, it can read the output current, output voltage, and calculated torque value of the M codes. (G9 compatible format) ----- Able to read and write data from/to major function codes. For function codes that can be read/written by the T-Link communications card, refer to Chapter 7, Table 7.7 "Function Code Group (Enhanced format)" (Enhanced format)
	Recovery from T-Link network breaks	o27 defines error processing that the inverter should perform when it detects a T-Link network break. If the inverter causes an alarm due to the error processing selected, removing the alarm factor and issuing a Reset command resumes the inverter operation.
	Checking alarms	Able to check the alarm contents using M codes. (G11 standard format and Enhanced format)

Item	Specifications
Protective functions	<p>\mathcal{E}_{r-4}:Option communications error (Communications card hardware error) (A communications error between the communications card and the inverter)</p> <p>\mathcal{E}_{r-5}:Option error (T-Link communications error) (A communications error between the MICREX and the communications card)</p>

**Tリンク通信カード / T-Link Communications Card
"OPC-TL"**

取扱説明書 / Instruction Manual

First Edition, August 2021

Fuji Electric Co., Ltd.

- この取扱説明書の一部または全部を無断で複製・転載することはお断りします。
- この説明書の内容は将来予告なしに変更することがあります。
- 本書の内容については、万全を期して作成いたしましたが、万一ご不審の点や誤り、記載もれなど、お気づきの点がありましたら、ご連絡ください。
- 運用した結果の影響については、上項にかかわらず責任を負いかねますのでご了承ください。

The purpose of this manual is to provide accurate information in the handling, setting up and operating of the T-Link Communications Card for the FRENIC series of inverters. Please feel free to send your comments regarding any errors or omissions you may have found, or any suggestions you may have for generally improving the manual.

In no event will Fuji Electric Co., Ltd. be liable for any direct or indirect damages resulting from the application of the information in this manual.

富士電機株式会社

〒141-0032 東京都品川区大崎一丁目11番2号
(ゲートシティ大崎イーストタワー)

URL <https://www.fujielectric.co.jp/>

Fuji Electric Co., Ltd.

Gate City Ohsaki, East Tower, 11-2, Osaki 1-chome,
Shinagawa-ku, Tokyo, 141-0032, Japan

URL <https://www.fujielectric.com/>
